



RINA

RINA HEAD OFFICE

STATEMENT

Following to the request of Messrs. **Hazard Control Technologies, Inc.-Europe s.r.l. Via Spallanzani 21-23, 19121 La Spezia**

IT IS STATED THAT:


The agent named F-500 produced by **Hazard Control Technologies, Inc. 150 Walter Way Fayetteville, GA 30214 USA**, can be used as an additive in the water based fire-fighting systems listed below to be used on board of all passenger ships, cargo ships, fishing vessels and yachts classed by RINA:

- Sprinkler systems for accommodation, service spaces and control stations other than those certified according to Res. A (800) or ISO 15371
- Drencher systems for special category spaces other than those certified according to MSC/Circ. 914

Drawings relevant to components and piping arrangement necessary to supply the agent to the fire-fighting systems are to be sent for approval for each single ship.

Genoa, March 24th 2005

Head of FPE Section



Francesco Tassinari